

Energy Audit

Skagway K-12 School

City of Skagway



*Final Report
February 2012*

Funded by:



Prepared by:

Alaska Energy Engineering LLC

25200 Amalga Harbor Road
Juneau, Alaska 99801

Tel/Fax: 907.789.1226
jim@alaskaenergy.us

Table of Contents

Section 1:	Executive Summary	2
Section 2:	Introduction	6
Section 3:	Energy Efficiency Measures	8
Section 4:	Description of Systems	14
Section 5:	Methodology	17
Appendix A:	Energy and Life Cycle Cost Analysis	20
Appendix B:	Energy and Utility Data	26
Appendix C:	Equipment Data	32
Appendix D:	Abbreviations	35

Audit Team

The energy audit is performed by Alaska Energy Engineering LLC of Juneau, Alaska. The audit team consists of:

- Jim Rehfeldt, P.E., Energy Engineer
- Jack Christiansen, Energy Consultant
- Brad Campbell, Energy Auditor
- Loras O'Toole P.E., Mechanical Engineer
- Will Van Dyken P.E., Electrical Engineer
- Curt Smit, P.E., Mechanical Engineer
- Philip Iverson, Construction Estimator
- Karla Hart, Technical Publications Specialist
- Jill Carlile, Data Analyst
- Grayson Carlile, Energy Modeler

Executive Summary

An energy audit of the Skagway K-12 School was performed by Alaska Energy Engineering LLC. The investment grade audit was funded by Alaska Housing Finance Corporation (AHFC) to identify opportunities to improve the energy performance of public buildings throughout Alaska.

Skagway School is a 45,518 square foot building that contains commons, classrooms, offices, a music room, a gym, a kitchen, a library, a shop, storage, and mechanical support spaces.

Building Assessment

The following summarizes our assessment of the building.

Envelope

The envelope of the Skagway School appears to be well preserved and is providing good service. The shell package is both attractive and efficient in design and construction. Building envelope issues include:

- **Complex Framing:** The design of the attic mechanical spaces required significant attention to detail during the construction phase to create a contiguous vapor barrier around the conditioned spaces. This is because the vapor barrier on the exterior walls and perimeter ceiling spaces must transition between all of the ceiling joists to the inside of the attic walls and maintain a seal while doing so. The large metal trusses and wood beams in the attic mechanical spaces that penetrate the vapor barrier surface compound the difficulty of this exercise. At the contact point of the drywall and the metal trusses or wooden beams, air infiltration could be felt when the AHU's were operated and the attic space became negatively pressurized. Air infiltration could be reduced along these intersections with the application of a spray foam sealant.
- **Failed Insulation:** Approximately 40 square feet of insulation have fallen down in the ceiling space above Room 316.
- **Arctic Entrances:** Double door entries are not installed at the ends of the hallways. As a result the main classroom hallways have been difficult to heat during periods of cold weather. School operations have had to be modified to limit the use of these hallway doors as 'emergency exits' only in an attempt to retain hallway heat. Double door entries should be included on all new construction.
- **Exterior Doors:** Exterior doors are not thermally broken. Future exterior door replacement selection should include this feature. Weather stripping on several doors is in poor condition and should be replaced.

Heating System

The school spaces are heated by two fuel oil boilers that provide heat to seven air handling unit systems, unit heaters, and perimeter hydronic systems.

In addition to meeting the heating demands of the school, the boilers have adequate capacity to supply all domestic hot water needs. However, a 250-gallon oil-fired hot water heater is currently utilized for this purpose. Oil-fired hot water heaters have cycling and standby losses and require maintenance, hence operational and maintenance efficiencies are reduced. Staff recognizes that the system is oversized and has isolated and shut down the original 500-gallon unit. The 250-gallon unit presently supplies the entire school. The original water heaters are sized to carry all of the domestic hot water needs, including an excessive anticipated shower water demand. Staff observed that the showers have only been used twice during this school year. This is a common defect in school domestic hot water system sizing; the hot water systems and subsequent boiler sizing are oversized based on a level of shower water consumption that never materializes. Because the boilers are operating the entire school year, both domestic hot water heaters could be removed and replaced with two 120-gallon indirect hot water heaters. In addition, because the boilers are oversized to meet an unnecessarily high hot water heating demand and they are now 28 years old, replacing one unit with a modern and more efficient properly sized unit should be considered.

The remainder of the fuel oil boiler heating system appears to be in good condition; however fairly simple improvements can be made to improve its effectiveness and efficiency. These are outlined in Section 3, Energy Efficiency Measures.

Ventilation Systems

The building has seven air handling unit systems, three of which are not in use. These include AHU-3 for the shop, AHU-6 for the locker rooms and AHU-7 for the music room. To reduce energy consumption, the remaining units (with the exception of AHU-5 for the gym) have schedules that turn off the units when the school is not occupied.

The ventilation to the classrooms has been reduced by closing the variable air volume boxes serving each classroom. While this measure and the reduction of AHU run-hours has been helpful from an operational cost perspective, air quality is reduced due to the lack of outside air exchanged in the school. The metric for air quality and the need for exchanging new air is the CO₂ level within a space. Guidelines suggest that CO₂ levels not exceed the ASHRAE action level of 1000 ppm.

The CO₂ levels were checked throughout the building and the following levels were found:

- Hallways, gym, lockers, multipurpose room, and offices 500-600 ppm
- Individual classes with 5-10 students 1000-1100 ppm
- Room 303 at the end of the hallway 1130 ppm

We recommend that AHU-1 and AHU-2 run times be increased and that air flow be reestablished to the classrooms to provide higher quality air to the high school and elementary wings of the building. While the CO₂ levels of the locker rooms were acceptable, we also recommend that AHU-6 and EF-1 be operated for at least half an hour per day to exchange the air in those spaces to help reduce moisture levels and the subsequent threat of mold/mildew issues.

Lighting

Interior lighting consists primarily of T12 and T8 fluorescent fixtures throughout the classrooms, commons, and office spaces. Staff has converted approximately 50% of the T12 fixtures to more efficient T8 lamps and expects to complete the conversion of all fixtures to T8's by next summer. All calculations of potential energy savings have been made using the more efficient T8 fixtures.

Metal halide lighting is used in the library and the gym. Existing gym lighting utilizes 28 pendant-mounted metal halide bulbs to light the space for approximately 60 hours per week to support school-hour class activities and after-school sports and community events. It is estimated that lighting hours could be reduced to 40 hours/week with the selection of a lamp that can start instantaneously because staff currently do not shut off metal halide fixtures once energized so they don't have to wait 10-15 minutes for restart. Only 50% of the lighting in the library is typically utilized because the 250-watt metal halide fixtures over light the space. Staff would like to replace the library metal halide lighting with a more efficient fixture that still provides the ability to be dimmed when necessary.

Exterior lighting primarily consists of metal halide lighting. Only 4 of the 24 outdoor architectural wall lights are utilized, and only for evenings with special events. Because lighting operational hours are controlled by staff, operational costs for lighting with existing infrastructure are kept to a minimum. Replacement of existing exterior metal halide fixtures with more efficient units is a solution for further reducing operational costs.

Summary

It was the assessment of the energy audit team that the majority of the building energy losses are due to the need to optimize air handling unit schedules and operations, the lack of occupancy sensor control of restroom lighting and fans, and the need to improve lighting efficiency in the gym space.

Energy Efficiency Measures (EEMs)

All buildings have opportunities to improve their energy efficiency. The energy audit revealed several opportunities in which an efficiency investment will result in a net reduction in long-term operating costs.

Behavioral and Operational EEMs

The following EEMs require behavioral and operational changes in the building use. The savings are not readily quantifiable but these EEMs are highly recommended as low-cost opportunities that are a standard of high performance buildings.

- EEM-1: Replace Broken Window
- EEM-2: Install Indirect Hot Water Heaters
- EEM-3: Clear Access to Perimeter Heaters
- EEM-4: Install Pipe and Valve Insulation

High and Medium Priority EEMs

The following EEMs are recommended for investment. They are ranked by life cycle savings to investment ratio (SIR). This ranking method places a priority on low cost EEMs which can be immediately funded, generating energy savings to fund higher cost EEMs in the following years. Negative values, in parenthesis, represent savings.

	25-Year Life Cycle Cost Analysis				SIR
	Investment	Operating	Energy	Total	
High Priority					
EEM-5: Isolate Lag Boiler	\$500	\$2,000	(\$39,700)	(\$37,200)	75.4
EEM-6: Electrical Room Heat Recovery	\$1,800	\$0	(\$23,100)	(\$21,300)	12.8
EEM-7: Replace Aerators	\$800	\$0	(\$6,400)	(\$5,600)	8.0
EEM-8: Perform Boiler Combustion Test	\$700	\$12,300	(\$15,100)	(\$2,100)	4.0
EEM-9: Optimize HVAC Systems	\$111,000	\$5,100	(\$410,400)	(\$294,300)	3.7
Medium Priority					
EEM-10: Upgrade Motors	\$6,000	\$0	(\$13,300)	(\$7,300)	2.2
EEM-11: Install Occupancy Sensors	\$16,200	(\$600)	(\$35,600)	(\$20,000)	2.2
EEM-12: Upgrade Gym Lighting	\$29,800	(\$2,100)	(\$59,600)	(\$31,900)	2.1
EEM-13: Boiler Room Heat Recovery	\$107,500	\$4,300	(\$187,000)	(\$75,200)	1.7
Totals*	\$274,300	\$21,000	(\$790,200)	(\$494,900)	2.8

*The analysis is based on each EEM being independent of the others. While it is likely that some EEMs are interrelated, an isolated analysis is used to demonstrate the economics because the audit team is not able to predict which EEMs an Owner may choose to implement. If several EEMs are implemented, the resulting energy savings is likely to differ from the sum of each EEM projection.

Summary

The energy audit revealed numerous opportunities for improving the energy performance of the building. We recommend that the behavioral and high priority EEMs be implemented now to generate energy savings from which to fund the medium priority EEMs.

Another avenue to consider is to borrow money from AHFCs revolving loan fund for public buildings. AHFC will loan money for energy improvements under terms that allow for paying back the money from the energy savings. More information on this option can be found online at http://www.ahfc.us/loans/akeerlf_loan.cfm.

Introduction

This report presents the findings of an energy audit of the Skagway K-12 School located in Skagway, Alaska. The purpose of this investment grade energy audit is to evaluate the infrastructure and its subsequent energy performance to identify applicable energy efficiencies measures (EEMs).

The energy audit report contains the following sections:

- **Introduction:** Building use and energy consumption.
- **Energy Efficiency Measures:** Priority ranking of the EEMs with a description, energy analysis, and life cycle cost analysis.
- **Description of Systems:** Background description of the building energy systems.
- **Methodology:** Basis for how construction and maintenance cost estimates are derived and the economic and energy factors used for the analysis.

BUILDING USE

Skagway School is a 45,518 square foot building that contains commons, classrooms, offices, a music room, a gym, a kitchen, a library, a shop, storage, and mechanical support spaces. The school is operated by 15 staff and attended by 58 students. The facility schedule is:

- Teachers: 8:00 am – 4:00 pm (M-F)
- Students: 8:15 am – 3:15 pm (M-F)
- Gym: Average of three hours per day between 8:00 am – 4:00 pm (M-F)
4:00 pm - 6:00 pm (M-F) Sports Practice

Building History

- 1983 – Original Construction
- 1984 – School Addition

Energy Consumption


The building energy sources include an electric service and a fuel oil tank. Fuel oil is used for the majority of the heating loads and domestic hot water while electricity serves all other loads. The following table shows annual energy use and cost.

Annual Energy Consumption and Cost

Source	Consumption	Cost	Energy, MMBtu
Electricity	234,000 kWh	\$50,200	798 32%
Fuel Oil	12,500 Gallons	<u>\$42,800</u>	<u>1,698</u> <u>68%</u>
Totals	-	\$93,000	2,496 100%



Electricity

This chart shows electrical energy use from 2008 to 2011. The effective cost—energy costs plus demand charges—is 21.4¢ per kWh.



Fuel Oil

This chart shows heating energy use from 2008 to 2011. The chart compares annual use with the heating degree days which is a measurement of the demand for energy to heat a building. A year with a higher number of degree days reflects colder outside temperatures and a higher heating requirement.



Cost of Heat Comparison

This chart shows a comparison of the current cost of fuel oil heat and electric heat. The comparison is based on a fuel oil conversion efficiency of 70% and electric boiler conversion efficiency of 95%. Fuel oil heat is currently less expensive than electric heat.

Energy Efficiency Measures

The following energy efficiency measures (EEMs) were identified during the energy audit. The EEMs are priority ranked and, where applicable, subjected to energy and life cycle cost analysis. Appendix A contains the energy and life cycle cost analysis spreadsheets.

The EEMs are grouped into the following prioritized categories:

- **Behavioral or Operational:** EEMs that require minimal capital investment but require operational or behavioral changes. The EEMs provide a life cycle savings but an analysis is not performed because the guaranteed energy savings is difficult to quantify.
- **High Priority:** EEMs that require a small capital investment and offer a life cycle savings. Also included in this category are higher cost EEMs that offer significant life cycle savings.
- **Medium Priority:** EEMs that require a significant capital investment to provide a life cycle savings. Many medium priority EEMs provide a high life cycle savings and offer substantial incentive to increase investment in building energy efficiency.

BEHAVIORAL OR OPERATIONAL

The following EEMs are recommended for implementation. They require behavioral or operational changes that can occur with minimal investment to achieve immediate savings. These EEMs are not easily quantified by analysis because they cannot be accurately predicted. They are recommended because they offer a life cycle savings, represent good practice, and are accepted features of high performance buildings.

EEM-1: Replace Broken Window

Purpose: A window on the west end of the elementary wing has a hole in the outer pane from a BB gun. Energy will be saved if broken window is repaired.

Scope: Repair broken window.

EEM-2: Install Indirect Hot Water Heaters

Purpose: The boilers have adequate capacity to heat the building and the domestic hot water. However, there are two oil-fired hot water heaters, of which only the smaller 250 gallon unit is in service. The direct heaters have higher heat loss and maintenance requirements than an indirect hot water heater. We recommend that when the oil-fired units reach the end of their service life they are replaced with two indirect hot water heaters.

Scope: When the oil-fired hot water heaters fail, replace them with indirect hot water heaters connected to the hydronic heating system.

EEM-3: Clear Access to Perimeter Heaters

Purpose: In some of the school rooms the furniture and shelving units are pushed up against the perimeter heaters. For the perimeter heating units to operate as effectively and efficiently as possible, they must have a clear path for air flow above and below them. In the stage room where bookshelves were blocking over half of the perimeter heaters, the staff member in the room needed to turn up the thermostat in the space during class hours. Energy will be saved if staff keeps access to the perimeter heaters open.

Scope: Educate staff of the importance to not block air flow to the base or top of the perimeter heating units and verify clear access on a routine basis.

EEM-4: Install Pipe and Valve Insulation

Purpose: Approximately 50 square feet of piping and valves are uninsulated in the boiler room, including the boiler expansion tank and aerator. Energy will be saved if these sections of piping and distribution components are optimally insulated.

Scope: Install insulation on piping and distribution components.

HIGH PRIORITY

The following EEMs are recommended for implementation because they are low cost measures that have a high savings to investment ratio. The EEMs are listed from highest to lowest priority. Negative values, in parenthesis, represent savings.

EEM-5: Isolate Lag Boiler

Purpose: During periods when the outside temperature is warm enough that only one boiler needs to be operated, circulating hot water through an isolated boiler in a dual boiler system can result in a 3% efficiency loss of the operable boiler due to the isolated boiler acting as a heat sink. Energy will be saved if only a single boiler is on line when temperatures permit.

Scope: Shut down and isolate the lag boiler when only a single boiler is needed to support building operations.

Annual Costs			Investment	Life Cycle Costs			SIR
Operating	Energy	Total		Operating	Energy	Total	
\$120	(\$1,400)	(\$1,280)	\$500	\$2,000	(\$39,700)	(\$37,200)	75.4

EEM-6: Electrical Room Heat Recovery

Purpose: Heat is generated by equipment operating in the electrical room. This heat is removed with an exhaust fan. Energy will be saved if this generated heat is returned within the shell of the building.

Scope: Re-route exhaust air ducting to return electrical room heat to the building.

Annual Costs			Investment	Life Cycle Costs			SIR
Operating	Energy	Total		Operating	Energy	Total	
\$0	(\$810)	(\$810)	\$1,800	\$0	(\$23,100)	(\$21,300)	12.8

EEM-7: Replace Aerators

Purpose: Energy and water will be saved by replacing the lavatory aerators with low-flow models.

Scope: Replace aerators on lavatories with water-conserving fixtures.

Annual Costs			Investment	Life Cycle Costs			SIR
Operating	Energy	Total		Operating	Energy	Total	
\$0	(\$250)	(\$250)	\$800	\$0	(\$6,400)	(\$5,600)	8.0

EEM-8: Perform a Boiler Combustion Test

Purpose: Operating the boiler with an optimum amount of excess air will improve combustion efficiency. Annual cleaning followed by a combustion test is recommended.

Scope: Annually clean and perform a combustion test on the boiler.

Annual Costs			Investment	Life Cycle Costs			SIR
Operating	Energy	Total		Operating	Energy	Total	
\$720	(\$530)	\$190	\$700	\$12,300	(\$15,100)	(\$2,100)	4.0

EEM-9: Optimize HVAC Systems

Purpose: The building utilizes constant volume heating and ventilation system units to provide conditioned air to interior spaces during the normal operational schedule, after school hours for activities, and as needed on weekends. Under most conditions the space occupancy throughout the majority of these operational hours is less than the design occupancy. This results in an unnecessarily high fuel and electric demand to support school operations. Energy will be saved if modifications are made to the respective air handling systems to reduce air flow when not needed.

Scope: Perform repairs as follows and recommission all air handling units to perform as a properly integrated system when completed.

- **AHU-1 and AHU-2**
 These systems are currently only operated to heat the corridors during cold weather. This operating mode does not properly ventilate the classrooms. We recommend operating the systems whenever the classrooms are occupied and improving their efficiency with the following:
 - Convert controls to DDC.
 - Remove corridors from the systems and operate fans with minimum 10% outside air for ventilation.
 - Replace turn vanes with VFD's to modulate fan speed.
- **AHU-4 (Cafeteria)**
 - Modify controls to provide sequential control of mixing dampers and heating coil to maintain room setpoint with CO₂ sensor override of mixing dampers.
- **AHU-5 (Gym)**
 - Modify controls to provide sequential control of mixing dampers and heating coil to maintain room setpoint with CO₂ sensor override of mixing dampers.
 - Install VFD to modulate air flow with cooling requirements; minimum flow of 50%.
- **Hydronic Heating System**
 - Operate one pump during mild weather and two pumps during cold weather.

Annual Costs			Life Cycle Costs				
Operating	Energy	Total	Investment	Operating	Energy	Total	SIR
\$300	(\$16,290)	(\$15,990)	\$111,000	\$5,100	(\$410,400)	(\$294,300)	3.7

MEDIUM PRIORITY

Medium priority EEMs will require planning and a higher level of investment. They are recommended because they offer a life cycle savings. The EEMs are listed from highest to lowest priority. Negative values, in parenthesis, represent savings.

EEM-10: Upgrade Motors to Premium Efficiency

Purpose: The equipment inspection identified five motors that can be upgraded with premium efficiency models to save energy. They are:

- AHU-5 7.5 HP
- CP-1 2 HP
- CP-3 3 HP
- AC-1 2 HP (x2)

Scope: Replace identified motors with premium efficiency motors.

Annual Costs			Investment	Life Cycle Costs			SIR
Operating	Energy	Total		Operating	Energy	Total	
\$0	(\$680)	(\$680)	\$6,000	\$0	(\$13,300)	(\$7,300)	2.2

EEM-11: Install Occupancy Sensors in Locker Rooms

Purpose: Lighting controls for the gym locker rooms are on a manual switch and frequently remain on even when the rooms are unoccupied. Energy will be saved if a motion detector is installed to minimize unnecessary lighting hours. We recommend that a 10-minute delay time is used on the occupancy sensor.

Lighting and exhaust in the toilet rooms are manually controlled from the wall switch and frequently remain on even when unoccupied. Energy will be saved if an occupancy sensor is installed to minimize unnecessary lighting and exhaust fan run hours. We recommend that a 5-minute delay time is used on the occupancy sensor.

Scope: Install an occupancy sensor in each locker room and toilet room to control lighting and the exhaust fans.

Annual Costs			Investment	Life Cycle Costs			SIR
Operating	Energy	Total		Operating	Energy	Total	
(\$30)	(\$1,360)	(\$1,390)	\$16,200	(\$600)	(\$35,600)	(\$20,000)	2.2

EEM-12: Upgrade Gym Lighting

Purpose: The existing gym lighting consists of 28 pendant-mounted metal halide fixtures. Staff currently keeps the lighting on all day despite variable occupancy so they don't have to wait 10-15 minutes for restart. We estimate that lighting hours could be reduced by 20 hours per week by using a lamp that can start instantaneously.

Similar light levels could be achieved with multi-lamp T5 lighting. Energy will be saved if the 28 metal halide light fixtures are replaced with 6-bulb T5 units.

Scope: Replace metal halide lights with 6-bulb T5 units.

Annual Costs			Investment	Life Cycle Costs			SIR
Operating	Energy	Total		Operating	Energy	Total	
(\$120)	(\$3,030)	(\$3,150)	\$29,800	(\$2,100)	(\$59,600)	(\$31,900)	2.1

EEM-13: Boiler Room Heat Recovery

Purpose: Heat generated by the boilers, equipment, and piping is currently rejected outdoors by VF-1. Energy will be saved if this generated heat is transferred as beneficial heat within the building.

Scope: Install an air-to-water heat pump in the boiler room. Distribute the heat via hydronic piping to a fan coil unit installed in each hallway. Replace VF-1 with a motorized damper that opens whenever a boiler is firing.

Annual Costs			Investment	Life Cycle Costs			SIR
Operating	Energy	Total		Operating	Energy	Total	
\$250	(\$5,410)	(\$5,160)	\$107,500	\$4,300	(\$187,000)	(\$75,200)	1.7

Description of Systems

ENERGY SYSTEMS

This section provides a general description of the building systems. Energy conservation opportunities are addressed in Section 3, Energy Efficiency Measures.

Building Envelope

Component	Description (inside to outside)	R-value	
		Existing	Optimal
Exterior Wall	5/8" Gyp. bd, 2"x8" studs 16" o.c., R-30 batt, 1/2" plywood, siding	R-32	R-30
Roof	24" o.c. joists w/ R-38 batt, 5/8" gyp. bd. (2 layers)	R-38	R-46
Floor Slab	4" Concrete slab-on-grade	R-10	R-10
Foundation	8" concrete w/ 2" perimeter insulation board	R-10	R-20
Windows	Double pane windows w/ storm window inserts	R-3	R-5
Doors	Steel doors w/ non-thermally broken frames	R-1.5	R-5

Heating System

The building is heated by two fuel oil boilers that provide heat to seven air handling unit systems, unit heaters, and perimeter hydronic systems. The heating system has the following pumps:

- CP-1 supplies heat to AHU's 1, 2, 3, 6, & 7
- CP-2 and CP-3 supply heat to AHU's 4 & 5 and the baseboard heaters
- HWCP-1 is the domestic hot water circulation pump

Ventilation Systems

Area	Fan System	Description
High School	AHU-1	12,000 cfm 10 hp constant volume air handling unit consisting of a heating coil, mixing box, filter section, and supply fan. Unit is currently serving just the hallway; classroom VAV boxes are disabled.
Elementary Hallway	AHU-2	12,000 cfm 10 hp constant volume air handling unit consisting of a heating coil, mixing box, filter section, and supply fan. Unit is currently serving just the hallway; classroom VAV boxes are disabled.
Shop	AHU-3	4,200 cfm 3 hp constant volume air handling unit consisting of a heating coil, mixing box, filter section, and supply fan (<i>not used</i>)
Multi-purpose Room	AHU-4	4,300 cfm 3 hp constant volume air handling unit consisting of a heating coil, mixing box, filter section, and supply fan
Gym	AHU-5	12,800 cfm 7.5 hp constant volume air handling unit consisting of a heating coil, mixing box, filter section, and supply fan
Locker Rooms	AHU-6	3,000 cfm 2 hp constant volume air handling unit consisting of a heating coil, mixing box, filter section, heat recovery from EF-1, and supply fan (<i>not used</i>)
Stage	AHU-7	3,900 cfm 2 hp constant volume air handling unit consisting of a heating coil, mixing box, filter section, and supply fan
Locker Rooms	EF-1	3,300 cfm 2 hp constant volume exhaust fan with heat recovery
New Addition Restrooms	EF-1a	500 cfm constant volume exhaust fan (<i>not used</i>)
High School Restrooms	EF-2	500 cfm constant volume exhaust fan
Janitors Closet	EF-4	170 cfm constant volume exhaust fan
Electrical Room	EF-5	160 cfm constant volume exhaust fan
Special Education Restroom	EF-6	145 cfm constant volume exhaust fan
Boiler Room	VF-1	5,100 cfm ½ hp constant volume exhaust fan

Domestic Hot Water System

The domestic hot water system consists of a 250-gallon oil-fired hot water heater that is on-line and a 500-gallon oil-fired hot water heater that is disconnected. The original water heaters are sized to carry the anticipated shower demand, but staff observed that the showers have only been used twice this school year. Because the boilers are also operating the entire school year, both domestic hot water heaters could be removed and replaced with two smaller indirect hot water heaters.

Automatic Control System

The building has a DDC system to control the operation of the heating and ventilation systems. Energy can be saved through further optimization of fan system scheduling combined with a retro-commissioning of the air handler systems.

Lighting

Interior lighting consists primarily of T12 and T8 fluorescent fixtures throughout the classrooms, commons, and office spaces. Staff has completed approximately 50% of the conversion of T12 lighting fixtures to the more efficient T8 models and expects to complete the conversion of all fixtures to T8's by next summer. All calculations of potential energy savings have been made using the more efficient T8 fixtures.

Metal halide lighting is used in the library and the gym. Existing gym lighting utilizes 28 pendant-mounted metal halide bulbs to light the space for approximately 60 hours per week to support school-hour class activities and after-school sports and community events. We estimate that lighting hours can be reduced to 40 hours/week with the selection of a lamp that can start instantaneously—staff does not currently shut off metal halide fixtures once they are energized so as to avoid a 10-15 minute wait for restart.

Only 50% of the lighting in the library is typically utilized because 250-watt metal halide fixtures were installed. Staff would like to replace the library metal halide lighting with a more efficient fixture that still provides the ability to be dimmed when necessary.

Exterior lighting consists primarily of metal halide lighting. Only four of the 24 outdoor architectural wall lights are utilized, and only for evenings with special events. Because lighting operational hours are controlled by staff, operational costs for lighting with existing infrastructure are kept to a minimum. Replacement of existing exterior metal halide fixtures with more efficient units is a solution for further reducing operational costs.

Electric Equipment

Commercial equipment for food preparation is located in the kitchen and surrounding spaces.

Methodology

Information for the energy audit was gathered through on-site observations, review of construction documents, and interviews with operation and maintenance personnel. The EEMs are evaluated using energy and life cycle cost analyses and are priority ranked for implementation.

Energy Efficiency Measures

Energy efficiency measures are identified by evaluating the building's energy systems and comparing them to systems in modern, high performance buildings. The process for identifying the EEMs acknowledges the realities of an existing building that was constructed when energy costs were much lower. Many of the opportunities used in modern high performance buildings—highly insulated envelopes, variable capacity mechanical systems, heat pumps, daylighting, lighting controls, etc.—simply cannot be economically incorporated into an existing building.

The EEMs represent practical measures to improve the energy efficiency of the buildings, taking into account the realities of limited budgets. If a future major renovation project occurs, additional EEMs common to high performance buildings should be incorporated.

Life Cycle Cost Analysis

The EEMs are evaluated using life cycle cost analysis which determines if an energy efficiency investment will provide a savings over a 25-year life. The analysis incorporates construction, replacement, maintenance, repair, and energy costs to determine the total cost over the life of the EEM. Future maintenance and energy cash flows are discounted to present worth using escalation factors for general inflation, energy inflation, and the value of money. The methodology is based on the National Institute of Standards and Technology (NIST) Handbook 135 – Life Cycle Cost Analysis.

Life cycle cost analysis is preferred to simple payback for facilities that have long—often perpetual—service lives. Simple payback, which compares construction cost and present energy cost, is reasonable for short time periods of 2-4 years, but yields below optimal results over longer periods because it does not properly account for the time value of money or inflationary effects on operating budgets. Accounting for energy inflation and the time value of money properly sums the true cost of facility ownership and seeks to minimize the life cycle cost.

Construction Costs

The cost estimates are derived based on a preliminary understanding of the scope of each EEM as gathered during the walk-through audit. The construction costs for in-house labor are \$60 per hour for work typically performed by maintenance staff and \$110 per hour for contract labor.

The cost estimate assumes the work will be performed as part of a larger renovation or energy efficiency upgrade project. When implementing EEMs, the cost estimate should be revisited once the scope and preferred method of performing the work has been determined. It is possible some EEMs will not provide a life cycle savings when the scope is finalized.

Maintenance Costs

Maintenance costs are based on in-house or contract labor using historical maintenance efforts and industry standards. Maintenance costs over the 25-year life of each EEM are included in the life cycle cost calculation spreadsheets and represent the level of effort to maintain the systems.

Energy Analysis

The energy performance of an EEM is evaluated within the operating parameters of the building. A comprehensive energy audit would rely on a computer model of the building to integrate building energy systems and evaluate the energy savings of each EEM. This investment grade audit does not utilize a computer model, so energy savings are calculated with factors that account for the dynamic operation of the building. Energy savings and costs are estimated for the 25-year life of the EEM using appropriate factors for energy inflation.

Prioritization

Each EEM is prioritized based on the life cycle savings to investment ratio (SIR) using the following formula:

$$\text{Prioritization Factor} = \text{Life Cycle Savings} / \text{Capital Costs}$$

This approach factor puts significant weight on the capital cost of an EEM, making lower cost EEMs more favorable.

Economic Factors

The following economic factors are significant to the findings.

Nominal Interest Rate: This is the nominal rate of return on an investment without regard to inflation. The analysis uses a rate of 5%.

Inflation Rate: This is the average inflationary change in prices over time. The analysis uses an inflation rate of 2%.

Economic Period: The analysis is based on a 25-year economic period with construction beginning in 2012.

Fuel Oil

Fuel oil currently costs \$4.03 per gallon for a seasonally adjusted blend of #1 and #2 fuel oil. The analysis is based on 6% fuel oil inflation which has been the average for the past 20-years.

Electricity

Electricity is supplied by Alaska Power and Telephone. The rate schedule is:

Alaska Power Company Bulk Power A-2	
Electricity (\$ / kWh)	\$0.0946
Cost of Power Adjustment (\$ / kWh)	\$0.0901
Demand (\$ / kW)	\$6.95
Customer Charge (\$ / mo)	\$84.52

Summary

The following table summarizes the energy and economic factors used in the analysis.

Summary of Economic and Energy Factors			
Factor	Rate or Cost	Factor	Rate or Cost
Nominal Discount Rate	5%	Electricity	\$0.214/kwh
General Inflation Rate	2%	Electricity Inflation	3%
Fuel Oil Cost (2012)	\$4.03/gal	Fuel Oil Inflation	6%

Appendix A

Energy and Life Cycle Cost Analysis

Skagway K-12 School

Basis

Economic

Study Period (years)	25	Nominal Discount Rate	5%	General Inflation	2%
----------------------	----	-----------------------	----	-------------------	----

Energy

	<u>2011 \$/gal</u>	<u>Fuel Inflation</u>	<u>2012 \$/gal</u>		
Fuel Oil	\$4.03	6%	\$4.27		
Electricity	<u>\$/kWh (2011)</u>	<u>\$/kW (2011)</u>	<u>Inflation</u>	<u>\$/kWh (2012)</u>	<u>\$/kW (2012)</u>
w/ Demand Charges	\$0.185	\$6.95	3%	\$0.191	\$7.16
w/o Demand Charges	\$0.214	-	3%	\$0.220	-

EEM-5: Isolate Lag Boiler

Energy Analysis

<u>Boiler</u>	<u>Input MBH</u>	<u>Loss %</u>	<u>Loss MBH</u>	<u>Hours, exist</u>	<u>Hours, new</u>	<u>kBtu</u>	<u>η boiler</u>	<u>Gallons</u>
B-1	1,905	0.5%	10	6,480	3,240	-30,857	68%	-328

Life Cycle Cost Analysis

	Year	Qty	Unit	Base Cost	Year 0 Cost
Construction Costs					
Establish procedure for isolating boiler	0	1	ea	\$500	\$500
Annual Costs					
Isolate boilers annually	1 - 25	2	hrs	\$60.00	\$2,043
Energy Costs					
Fuel Oil	1 - 25	-328	gal	\$4.27	(\$39,671)
Net Present Worth					(\$37,100)

EEM-6: Electrical Room Heat Recovery

Energy Analysis

Fuel Oil	<u>Watts</u>	<u>Hours</u>	<u>MBH</u>	<u>kBtu</u>	<u>η boiler</u>	<u>Gallons</u>
	-600	8,760	-2	-17,933	68%	-190

Life Cycle Cost Analysis

	Year	Qty	Unit	Base Cost	Year 0 Cost
Construction Costs					
Exhaust fan ductwork and exhaust grille	0	1	LS	\$1,000	\$1,000
Estimating contingency	0			15%	\$150
Overhead & profit	0			30%	\$345
Design fees	0			10%	\$150
Project management	0			8%	\$132
Energy Costs					
Fuel Oil	1 - 25	-190	gal	\$4.27	(\$23,056)
Net Present Worth					(\$21,300)

Skagway K-12 School

EEM-7: Replace Aerators

Energy Analysis

Fixture	Gallons per Use		Uses/day	Days	Water.Gals	% HW	η boiler kBTU	68% Gallons
	Existing	Proposed						
Lavatories	0.3	0.2	200	198	-7,128	80%	-3,805	-40
					-7,128			-40

Life Cycle Cost Analysis	Year	Qty	Unit	Base Cost	Year 0 Cost
Construction Costs					
Replace lavatory aerators	0	23	ea	\$35	\$805
Energy Costs					
Water	1 - 25	-7	kgals	\$10.960	(\$1,536)
Fuel Oil	1 - 25	-40	gal	\$4.27	(\$4,891)
Net Present Worth					(\$5,600)

EEM-8: Perform Boiler Combustion Test

Energy Analysis

Annual Gal	% Savings	Savings Gal
12,500	-1.0%	-125

Life Cycle Cost Analysis	Year	Qty	Unit	Base Cost	Year 0 Cost
Construction Costs					
Purchase combustion analyzer	0	1	LS	\$700	\$700
Annual Costs					
Clean and combustion test boiler	1 - 25	12	hrs	\$60.00	\$12,259
Energy Costs					
Fuel Oil	1 - 25	-125	gal	\$4.27	(\$15,135)
Net Present Worth					(\$2,200)

Skagway K-12 School

EEM-9: Optimize HVAC Systems

Energy Analysis

Fan	Case	CFM	ΔP	η _{fan}	BHP	η _{motor}	kW	Hours	kWh
AHU-1	Existing	-12,000	3.00	60%	-9	91%	-8	1,620	-12,537
	Optimized	8,000	2.00	60%	4	91%	3	1,620	5,572
AHU-2	Existing	-12,000	3.00	60%	-9	91%	-8	1,620	-12,537
	Optimized	8,000	2.00	60%	4	91%	3	1,620	5,572
AHU-5	Existing	-12,800	1.60	55%	-6	90%	-5	1,260	-6,119
	Optimized	8,000	1.25	55%	3	90%	2	1,260	2,988
S-3	Existing	-6,000	3.00	55%	-5	89%	-4		0
	Optimized	4,000	2.00	55%	2	93%	2		0
S-6	Existing	-2,400	1.25	50%	-1	86%	-1		0
	Optimized	1,500	0.75	50%	0	86%	0		0
S-7	Existing	-3,600	1.00	50%	-1	88%	-1		0
	Optimized	1,800	0.75	50%	0	88%	0		0
							-15		-17,061

Ventilation		SA CFM	MAT	T _{room}	MBH	Hours	kBtu	η boiler	Gallons
AHU-1	Existing	-8,000	60	70	-86	1,620	-139,968	68%	-1,486
	Optimized	8,000	64	70	52	1,620	83,981	68%	892
AHU-2	Existing	-8,000	60	70	-86	1,620	-139,968	68%	-1,486
	Optimized	8,000	64	70	52	1,620	83,981	68%	892
AHU-4	Existing	-4,300	45	70	-116	540	-62,694	68%	-666
	Optimized	4,300	62	70	37	540	20,062	68%	213
AHU-5	Existing	-12,800	62	70	-111	1,260	-139,346	68%	-1,480
	Optimized	8,000	64	70	52	1,260	65,318	68%	694
S-7	Existing	-3,600	60	70	-39		0	68%	0
	Optimized	1,800	65	70	10		0	68%	0
							-228,634		-2,428

Pumping Energy

Pump	GPM	Head	η _{pump}	BHP	η _{motor}	kW	Hours	kWh
CP-1	-116	30	65%	-1.8	89%	-1.5	6,480	-9,838
CP-3	-160	40	75%	-2.9	89%	-2.4	6,480	-15,680
CP-1	116	30	65%	1.8	89%	1.5	5,040	7,651
CP-3	160	40	75%	2.9	89%	2.4	4,320	10,453
-7,413								

Life Cycle Cost Analysis

	Year	Qty	Unit	Base Cost	Year 0 Cost
Construction Costs					
Convert AHU-1 and AHU-2 to DDC	0	20	pts	\$1,500	\$30,000
Install VFD for AHU-1 and AHU-2	0	2	LS	\$7,500	\$15,000
AHU-4 and AHU-5: Install CO2 sensor and modify controls	0	2	ea	\$5,000	\$10,000
Install VFD for AHU-5	0	1	LS	\$7,500	\$7,500
Estimating contingency				15%	\$9,375
Overhead & profit				30%	\$21,563
Design fees				10%	\$9,344
Project management				8%	\$8,223
Annual Costs					
VFD Maintenance	1 - 25	3	LS	\$100.00	\$5,108
Energy Costs					
Electric Energy	1 - 25	-24,473	kWh	\$0.191	(\$91,671)
Electric Demand	1 - 25	-176	kW	\$7.16	(\$24,787)
Fuel Oil	1 - 25	-2,428	gal	\$4.27	(\$293,942)
Net Present Worth					(\$294,300)

Skagway K-12 School

EEM-10: Upgrade Motors

Energy Analysis

Equip	Number	HP	η_{old}	η_{new}	kW	Hours	kWh
AC-1	1	2	80.8%	86.5%	-0.09	2,920	-248
CP-1	1	2	78.5%	89.5%	-0.16	6,480	-1,063
CP-2	1	3	81.4%	89.5%	-0.18	6,480	-1,175
AHU-5	1	7.5	81.5%	91.7%	-0.57	1,260	-719
					-1.0		-3,206

Life Cycle Cost Analysis

	Year	Qty	Unit	Base Cost	Year 0 Cost
Construction Costs					
Replace motor		0	3	955	\$2,865
Replace motor		0	1	970	\$970
Replace motor		0	1	1,690	\$1,690
Project management		0		8%	\$442
Energy Costs					
Electric Energy	1 - 25	-3,206	kWh	\$0.191	(\$12,007)
Electric Demand	1 - 25	-9	kW	\$7.16	(\$1,268)
Net Present Worth					(\$7,300)

EEM-11: Install Occupancy Sensors

Energy Analysis

Location	Type	# Fixtures	Lamp	Lamp, watts	Fixture Watts	Hours, exist	Hours, new	Savings, kWh
Lockers	Surface	22	2T8	64	74	-1,620	540	-1,749
Toilets	Surface	16	2T8	64	74	-1,620	720	-1,060

Lamp Replacement

Location	# Fixtures	Lamp	# Lamps	Life, hrs	Lamps/yr	\$/lamp	\$/Replace
Lockers	22	2T8	1	30,000	-0.79	\$4	\$15
Toilets	16	2T8	1	30,000	-0.48	\$4	\$15

Exhaust Fans

Unit	CFM, ex	CFM, new	ΔT	MBH	Hours	kBtu	η boiler	Gallons
EF-1A	500	200	20	-7	1,710	-11,286	68%	-120
EF-2	500	200	20	-7	1,710	-11,286	68%	-120
				-13				-240

Life Cycle Cost Analysis

	Year	Qty	Unit	Base Cost	Year 0 Cost
Construction Costs					
Install occupancy sensors		0	6	\$1,500	\$9,000
Estimating contingency		0		15%	\$1,350
Overhead & profit		0		30%	\$3,105
Design fees		0		10%	\$1,346
Project management		0		8%	\$1,184
Adjust photocell		0	1	\$200	\$200
Annual Costs					
Lamp replacements	1 - 25	-1.27	lamps	\$26.00	(\$563)
Energy Costs					
Electric Energy	1 - 25	-1,749	kWh	\$0.191	(\$6,550)
Fuel Oil	1 - 25	-240	gal	\$4.27	(\$29,020)
Net Present Worth					(\$19,900)

Skagway K-12 School

EEM-12: Upgrade Gym Lighting

Energy Analysis

Type	# Fixtures	Lamp	Lamp watts	Fixture Watts	kW	Hours exist	Hours new	Savings kWh
MH	-28	MH	400	460	-13	2,400	0	-30,912
T5	28	6T5	310	357	10	0	1,600	15,971
					-3			-14,941

Lamp Replacement

# Fixtures	Lamp	# Lamps	Life. hrs	Replace/yr	\$/lamp replace
28	MH	-1	20,000	-3.36	\$30
28	6T5	6	30,000	1.49	\$24

Life Cycle Cost Analysis	Year	Qty	Unit	Base Cost	Year 0 Cost
Construction Costs					
Replace 400 watt MH with T5 Fluorescent	0	28	LS	\$600	\$16,800
Estimating contingency	0			15%	\$2,520
Overhead & profit	0			30%	\$5,796
Design fees	0			10%	\$2,512
Project management	0			8%	\$2,210
Annual Costs					
Existing lamp replacement, 400 watt MH	1 - 25	-3.36	replacements	\$60.00	(\$3,433)
New lamp replacement, T5	1 - 25	1.49	replacements	\$54.00	\$1,373
Energy Costs					
Electric Energy	1 - 25	-14,941	kWh	\$0.191	(\$55,965)
Electric Demand	1 - 25	-26	kW	\$7.16	(\$3,670)
Net Present Worth					(\$31,900)

EEM-13: Boiler Room Heat Recovery

Energy Analysis

Heat Recovery

Input, MBH	Jacket Loss	MBH	Hours	Loss, kBtu	Factor	Recovery, kBtu	η boiler	Gallons
3,810	-1.0%	-38	6,480	-246,857	75%	-185,143	82%	-1,630

Heat Pump Energy

Recovery, kBtu	COP	kWh	HP Heat, kBtu	η boiler	Gallons
-185,143	3	18,087	61,714	82%	-543

Life Cycle Cost Analysis	Year	Qty	Unit	Base Cost	Year 0 Cost
Construction Costs					
Boiler room heat pump	0	1	LS	\$15,000	\$15,000
Hallway fan coil unit	0	2	LS	\$6,000	\$12,000
Motorized combustion air damper	0	1	LS	\$3,500	\$3,500
Piping between heat pump and fan coil	0	1	LS	\$22,000	\$22,000
Controls	0	1	LS	\$8,000	\$8,000
Estimating contingency	0			15%	\$9,075
Overhead & profit	0			30%	\$20,873
Design fees	0			10%	\$9,045
Project management	0			8%	\$7,959
Annual Costs					
Heat pump maintenance	1 - 25	1	LS	\$250.00	\$4,257
Energy Costs					
Electric Energy	1 - 25	18,087	kWh	\$0.191	\$67,751
Electric Demand	1 - 25	60.0	kW	\$7.16	\$8,443
Fuel Oil	1 - 25	-2,174	gal	\$4.27	(\$263,186)
Net Present Worth					(\$75,300)

Appendix B

Energy and Utility Data

Alaska Energy Engineering LLC

Billing Data

25200 Amalga Harbor Road Tel/Fax: 907-789-1226
Juneau, Alaska 99801 jim@alaskaenergy.us

Skagway K-12 School

ELECTRIC RATE

Alaska Power Company Bulk Power A-2		Haines Skagway
Electricity (\$ / kWh)		\$0.0946
Cost of Power Adjustment (\$ / kWh)		\$0.0901
Demand (\$ / kW)		\$6.95
Customer Charge (\$ / mo)		\$84.52
Sales Tax (%)		0.0%

ELECTRICAL CONSUMPTION AND DEMAND



Month	2008		2009		2010		2011		Average
	kWh	kW	kWh	kW	kWh	kW	kWh	kW	
Jan	23,400	104	22,400	94	21,200	88	21,600	84	22,150
Feb	28,800	104	25,000	82	25,200	82	25,400	86	26,100
Mar	24,400	98	25,400	88	20,200	80	21,200	86	22,800
Apr	23,400	86	19,600	86	21,000	80	20,600	80	21,150
May	23,400	86	21,800	88	20,600	80	21,600	78	21,850
Jun	10,000	80	11,800	72	12,200	72	13,600	78	11,900
Jul	8,000	32	9,000	36	9,000	34	12,200	50	9,550
Aug	12,200	54	8,400	36	8,400	32	15,000	58	11,000
Sep	21,200	82	19,800	78	19,600	72	19,200	66	19,950
Oct	23,400	88	22,000	82	20,800	76	19,200	44	21,350
Nov	24,400	84	23,200	82	21,600	74	22,400	74	22,900
Dec	23,800	88	23,600	86	23,400	86	22,800	74	23,400
Total	246,400		232,000		223,200		234,800		234,100
Average	20,533	82	19,333	76	18,600	71	19,567	72	19,508
Load Factor	34%		35%		36%		37%		75



ELECTRIC BILLING DETAILS

Electrical costs are based on the current electric rates.


Month	2010				2011				% Change
	Energy	Demand	Cust & Tax	Total	Energy	Demand	Cust & Tax	Total	
Jan	\$3,916	\$612	\$85	\$4,612	\$3,990	\$584	\$85	\$4,658	1.0%
Feb	\$4,654	\$570	\$85	\$5,309	\$4,691	\$598	\$85	\$5,374	1.2%
Mar	\$3,731	\$556	\$85	\$4,371	\$3,916	\$598	\$85	\$4,598	5.2%
Apr	\$3,879	\$556	\$85	\$4,519	\$3,805	\$556	\$85	\$4,445	-1.6%
May	\$3,805	\$556	\$85	\$4,445	\$3,990	\$542	\$85	\$4,616	3.8%
Jun	\$2,253	\$500	\$85	\$2,838	\$2,512	\$542	\$85	\$3,139	10.6%
Jul	\$1,662	\$236	\$85	\$1,983	\$2,253	\$348	\$85	\$2,685	35.4%
Aug	\$1,551	\$222	\$85	\$1,858	\$2,771	\$403	\$85	\$3,258	75.3%
Sep	\$3,620	\$500	\$85	\$4,205	\$3,546	\$459	\$85	\$4,089	-2.7%
Oct	\$3,842	\$528	\$85	\$4,454	\$3,546	\$306	\$85	\$3,937	-11.6%
Nov	\$3,990	\$514	\$85	\$4,588	\$4,137	\$514	\$85	\$4,736	3.2%
Dec	\$4,322	\$598	\$85	\$5,004	\$4,211	\$514	\$85	\$4,810	-3.9%
Total	\$ 41,225	\$ 5,949	\$ 1,014	\$ 48,188	\$ 43,368	\$ 5,963	\$ 1,014	\$ 50,345	4.5%
Average	\$ 3,435	\$ 496	\$ 85	\$ 4,016	\$ 3,614	\$ 497	\$ 85	\$ 4,195	4.5%
Cost (\$/kWh)				\$0.216	86%	12%	2%	\$0.214	-0.7%

Skagway K-12 School





Skagway K-12 School




Year	Fuel Oil	Degree Days
2,008	13,990	9,093
2,009	12,986	9,284
2,010	11,700	9,013
2,011	11,300	8,729

Annual Energy Consumption and Cost

<u>Energy</u>	<u>Cost</u>	<u>\$/MMBtu</u>	<u>Area</u>	<u>ECI</u>	<u>EUI</u>
Fuel Oil	\$4.03	\$41.57	45,518	\$2.21	55
Electricity	\$0.214	\$66.15			

Annual Energy Consumption and Cost

<u>Source</u>	<u>Consumption</u>	<u>Cost</u>	<u>Energy, MMBtu</u>	
Electricity	234,000 kWh	\$50,200	800	32%
Fuel Oil	12,500 Gallons	\$50,400	1,700	68%
Totals		\$100,600	2,500	100%



Appendix C

Equipment Data

Skagway K-12 School - Major Equipment Inventory

Unit ID	Location	Function	Make	Model	Capacity	Motor HP / Volts / RPM / Effic	Notes
AHU-1	Central Fan Room	High School Hallway	Bohn	VCS26ALF	12000 CFM	10 HP/ 208 V/ 1745 RPM/ 85.6%	
AHU-2	Central Fan Room	Elementary Hallway	Bohn	HD26ALF	12000 CFM	10 HP/ 208 V/ 1745 RPM/ 85.6%	
AHU-3	Central Fan Room	Shop	Bohn	HD08ALF	4200 CFM	3 HP/ 208 V/ 1750 RPM/ 82.5%	
AHU-4	Central Fan Room	Multipurpose Room	Bohn	VCS08ACF	4300 CFM	3 HP/ 208 V/ 1750 RPM/ 82.5%	
AHU-5	Central Fan Room	Gym	Bohn	VCS26ALF	12800 CFM	7.5 HP/ 208 V/ 1765 RPM/ 81.5%	
AHU-6	Central Fan Room	Locker Rooms	Bohn	HD06ALF	3000 CFM	2 HP/ 208 V/ 1725 RPM/ 78.5%	
AHU-7	Central Fan Room	Stage	Bohn	HD08ALF	3900 CFM	2 HP/ 208 V/ 1760 RPM/ 78.5%	
EF-1	Gym Fan Room	Locker Rooms	Trane	UI6PT3-FC	3300 CFM	2 HP/ 208 V/ 1725 RPM/ 78.5%	
EF-1A	New Addition	Restrooms	Penn	Zephyr Z12TD	500 CFM	120 V/ 208 Watts	
EF-2	High School Wing	Restrooms	Penn	Zephyr Z12TD	500 CFM	120 V/ 208 Watts	
EF-4	Janitor Closet	Janitor Closet Exhaust	Penn	Zephyr Z8	170 CFM	120 V/ 105 Watts	Operates off light switch
EF-5	Electrical Room	Electrical Room	Penn	Zephyr Z8	160 CFM	120 V/ 105 Watts	
EF-6	Special Ed. Restroom	Restroom Exhaust	Penn	Zephyr Z8	145 CFM	120 V/ 105 Watts	Operates off light switch
VF-1	Boiler Room	Ventilation Air	Greenheck	SDP-30-6-15	5100 CFM	1/2 HP/ 120 V/47%	
B-1	Boiler Room	Boiler	Weil McLain	H-886-S-W	1600 MBH		
B-2	Boiler Room	Boiler	Weil McLain	H-886-S-W	1600 MBH	Lag boiler Not Isolated	
CP-1	Boiler Room	AHU 1,2,3,6,7	B&G	2AC 6 1/8 BF	116 GPM	2 HP/ 208 V/ 1725 RPM/ 78.5%	
CP-2	Boiler Room	AHU 4, 5, Baseboard	B&G	2.5AB 6 5/8 BF	160 GPM	3 HP/ 208 V/ 1730 RPM/ 78.5%	
CP-3	Boiler Room	AHU 4, 5, Baseboard	B&G	2.5AB 6 5/8 BF	160 GPM	3 HP/ 208 V/ 1730 RPM/ 78.5%	
HWH-1	Boiler Room	Hot Water Heater	Pvi	3.8-N-500-A-D	500 Gallon	540 MBH	Direct fired fuel oil WH; Not used
HWH-2	Boiler Room	Hot Water Heater	Pvi	27N250A-MXO	250 Gallon	270 MBH / 1/3 HP/60%	Direct fired fuel oil WH

Skagway K-12 School - Major Equipment Inventory								
Unit ID	Location	Function	Make	Model	Capacity	Motor HP / Volts / RPM / Effic	Notes	
HWCP-1	Boiler Room	Hot Water Circulation Pump	B&G	LR-20WR	2 GPM	115 V		
ICV-1	Central Fan Room	Central Vacuum	Spencer	307740	150 CFM	5 HP/ 208 V/ 3500 RPM/83.3%		
AC-1	Boiler Room	Air Compressor	Quincy	00020008D00327	100 CFM	2 HP/ 208 V/ 1750 RPM/ 78.5% (x2)		
Freezer	Shop	Food Storage	Heat Craft	LET120BK		208 V/ 11.7 pmps/ 2700 Watts		
EF-7	Shop	Paint Fume Exhaust				2 HP/ 208 V/ 1725 RPM/80.8%		

Abbreviations

AHU	Air handling unit	KVA	Kilovolt-amps
BTU	British thermal unit	kW	Kilowatt
BTUH	BTU per hour	kWh	Kilowatt-hour
CBJ	City and Borough of Juneau	LED	Light emitting diode
CMU	Concrete masonry unit	MBH	1,000 Btu per hour
CO ₂	Carbon dioxide	MMBH	1,000,000 Btu per hour
CUH	Cabinet unit heater	OAD	Outside air damper
DDC	Direct digital controls	PSI	Per square inch
DHW	Domestic hot water	PSIG	Per square inch gage
EAD	Exhaust air damper	RAD	Return air damper
EEM	Energy efficiency measure	RF	Return fan
EF	Exhaust fan	SIR	Savings to investment ratio
Gyp Bd	Gypsum board	SF	Supply fan
HVAC	Heating, Ventilating, Air-conditioning	UV	Unit ventilator
HW	Hot water	VAV	Variable air volume
HWRP	Hot water recirculating pump	VFD	Variable frequency drive